

CHIMNEY WITH PROPER FLUE LINER OR CLASS B VENT

MIN. SLOPE OF 1/4" PER FT.

OUTGOING HOT WATER

INCOMING COLD WATER

BALL VALVE

3" OR 4" VENT PIPE

3/4" COPPER


SLIP (REPAIR) COUPLING

PLASTIC LINED GALVANIZED NIPPLE TO SLOW CORROSION

ALWAYS CONSULT YOUR PLUMBING INSPECTOR. LOCAL CODES VARY.

GAS SHUTOFF VALVE

DRAFT HOOD



TEMPERATURE AND PRESSURE RELIEF VALVE

SUPPORT REQUIRED IN EARTHQUAKE REGIONS

DISCHARGE LINE




KEEP FLAMMABLE AND CORROSIVE MATERIALS AWAY FROM WATER HEATER. THIS INCLUDES GASOLINE, SOLVENTS, PAINT, AEROSOLS AND BLEACH.

FLEXIBLE STAINLESS STEEL GAS CONNECTOR

STEEL OR COPPER GAS PIPE

UNION



DO NOT KINK

GAS AND TEMPERATURE CONTROLS

DRAIN VALVE

6" GAP TO FLOOR

FLEXIBLE STAINLESS STEEL IS ALTERNATIVE GAS CONNECTOR, IF APPROVED BY LOCAL CODES.

1-1/2" MIN.

PAN REQUIRED WHERE LEAKAGE CAN CAUSE DAMAGE (WOOD FLOORS). EXTEND DISCHARGE LINE TO DRAIN AS WELL.

ELEVATE GAS WATER HEATER AT LEAST 18" ABOVE THE FLOOR IN PLACES WHERE FLAMMABLE FUMES MAY OCCUR (GARAGES).

